Jacobson & Greiner

Group of Companies



SAFE WORK PRACTICE

TITLE	Fire Hydrants
GENERAL	Protecting workers from injuries associated with the operation of fire hydrants
APPLICATION	The use of fire hydrants is an integral part of the industry
PROTECTIVE	Safe work procedures
MECHANISMS	Manufacturer specifications
	PPE
	ERP (Emergency Response Plan)
SELECTION	As per safe work procedure
AND USE	Manufacturer specifications
MANAGEMENT	Management are responsible to facilitate and/or provide proper instruction to
RESPONSIBILITY	their workers on protection requirements and training
FOREMANS	Foremen are responsible to facilitate and/or provide proper instruction to their
RESPONSIBILITY	workers on the jobsite
	Work site hazard assessment
	 Perform a visual inspection of the fire hydrant, before working on it.
	2. Ensure the hydrant is shut off, "before" removing the port cap(s).
	3. Position yourself to the side, away from the port cap(s) when removing
	them. Never position your head near any of the port caps.
	4. Remove the port cap(s) "slowly".
	5. Remove all port caps, check the threads and ensure each port cap has a rubber gasket.
	6. Reposition and tighten all unused port caps, attach the hose and gate
	valve to the desired discharge port and tighten it "before" opening the
	hydrant.
	7. Attach a water control device to the hose line "before" opening the hydrant.
	8. When using a Fire Hydrant, open the hydrant "slowly" and "fully".
	Never straddle or step over a hose when it is "charged" with water
	under pressure.
	10. After use, close the hydrant "slowly" and "fully".11. Remove the pressure from the hose by opening the water control
	device.
	12. Check to confirm the hydrant is draining properly by placing your bare
	hand over the discharge port. You should feel suction.
	13. Do not reapply the port cap to this discharge port until there is no
	longer any suction and the water level "inside the hydrant barrel" has
	been checked with a weighted string.
	To the transfer of the transfe

Created On: December 2012