



Handling Propane

Developed by:		Approved by:	Date created:	Last revision:
Jason M. Moffatt		G. Kaluzniak	January , 2016	December 1, 2022
Possible Hazards Present		Personal Protection Required		Additional Training
<ul style="list-style-type: none"> - Muscle strain - Fire hazard - Explosion - Burns 		<ul style="list-style-type: none"> - Fire Extinguisher - Gloves - Steel Toed Boots - Eye Protection 		<ul style="list-style-type: none"> - WHMIS
<ol style="list-style-type: none"> 1. Ensure that tank valves and regulators are not removed before moving tank. 2. Attach nylon sling in a "choker" fashion for loading, unloading or moving tank. 3. Make sure tank is stored in an upright position on level ground at proper temperature. 4. Keep clear of flames, sparks and cigarettes. 				
<p>Documentation/Legislation Workplace Safety and Health Regulation, M.R. 217/2006</p> <p>6 Personal Protective Equipment 8 Musculoskeletal Injuries 19.10 Compressed Gas Equipment 25 Workplace Hazardous Materials Information Systems</p>			<p style="text-align: center;">This Safe Work Procedure will be reviewed anytime the task, equipment or materials change and at a minimum every three years.</p>	