



SAFE WORK PRACTICE

TITLE	Propane Cylinders
GENERAL	Protecting workers from injury associated with care and handling of propane cylinders
APPLICATION	No person shall handle or use propane cylinders until they are fully aware of potential hazards and the precautions necessary to handle propane safely.
PROTECTIVE MECHANISMS	Propane Procedure TDG (Transportation of dangerous goods) WHMIS MSDS PPE Emergency Response Plan
SELECTION AND USE	Manufacture's specifications As per safe work procedure
SUPERVISOR RESPONSIBILITY	To facilitate and/or provide proper instruction and training on protection equipment and handling TDG Compliant
WORKER RESPONSIBILITY	<ol style="list-style-type: none"> 1. Ensure WHMIS and TDG labels are appropriately attached and visible. 2. Cylinders must be secured and transported in an upright position in a well ventilated area. Valve cap or collar and regulator removed. 3. A regulator must be installed prior to use. 4. When Checking for leaks use a soapy solution. 5. When not in use, cylinders are to be secured in upright position, valve closed, regulator removed. 6. Cylinder not to be used if shoulder/stamp is not legible. 7. When not in use, a plug or cap must be used to seal the valve opening. 8. Cylinder must not be painted in any fashion.