

Propane – Handling

	P	Approved by:	Date create	ed:	Last revision:
Developed by:					
Jason M. Moffatt	G. Kaluzniak		January , 2016		December 1, 2022
Possible Hazards Present		Personal Protection		Additional Training	

Possible Hazards Present		ent Personal Protection	Additional Training
		Required	
	 Toxic Fumes 	- Toxic Fumes - CSA Footwear	
	 Explosions 	 CSA Safety Glasses 	3
	- Fire	- Gloves	

- 1. Ensure outdated tanks are replaced with new tanks.
- 2. Store all tanks in an upright position.
- 3. Secure tanks properly in an upright position.
- 4. Ensure valve guards are installed when transporting tanks.
- 5. Store in well ventilated area away from all flames or sparks.

Documentation/Legislation

Workplace Safety and Health Regulation, M.R. 217/2006

7 Storage of Materials, Equipment, Machines and Tools

This Safe Work Procedure will be reviewed anytime the task, equipment or materials change and at a minimum every three years.